

NFPA 70 NEC  
 IFC 319 Mobile Food Preparation vehicles  
 NFPA 58 LP Gas Code  
 NFPA 96

## FOOD TRUCK / CONCESSION TRAILERS / TENTS

VENDOR NAME: \_\_\_\_\_ DATE: \_\_\_\_\_

CONTACT NAME: \_\_\_\_\_ PHONE#: ( ) \_\_\_\_\_

ITEM	SAT	UNSAT	N/A	ITEM	SAT	UNSAT	N/A
<b>GENERAL SAFETY</b>				<b>FIRE SUPPRESSION SYSTEM</b>			
1) Current City Business License				1) Portable ABC Fire Extinguisher	IFC 319.4.2	NFPA 96 10.9	
2) Current Health Department Permit				A. Minimum 2A:10BC (Non Propane Units)			
3) No public seating inside unit				B. Minimum 4A:40BC (Propane Units)			
4) Minimum 10 ft. clearance around unit	NFPA 96 17.2.1			C. Travel distance <30 feet			
5) Adequate fire department access				D. Current certification tag	NFPA 10		
<b>POWER SOURCE (GENERATORS) &amp; FUEL SUPPLY</b>				E. Visible and accessible	NFPA 10		
1) Fuel tanks filled to capacity				2) Portable Class K Fire Extinguisher	IFC 319.4.2	NFPA 96 11.7.2	
<b>REFUELING IS ONLY ALLOWED DURING NON-OPERATING HOURS</b>				A. Minimum 2.5 gallon Class K			
2) Portable Generator Exhaust System	Does not apply to vehicle mounted unit			B. Travel distance <30 feet			
A. Min 10 ft from opening and intakes	NFPA 96 17.2.3			C. Current certification tag	NFPA 10		
B. Min 10 ft from means of egress	NFPA 96 17.2.1			D. Visible and accessible	NFPA 10		
C. Directed away from buildings/ vendors	NFPA 96 17.2.1			3) Hood System			
3) Electrical receptacles GFCI protected	NFPA 70 210.8 B			<b>TYPE 1 HOOD SYSTEM REQUIRED FOR FRYING OR GRILLING OPERATIONS</b>			
A. No open junction boxes/unsafe conditions				A. Current certification tag (6 Months)	NFPA 96		
<b>LP-GAS SYSTEM</b> Pressure test conducted?	NFPA 58 6.11.4	IFC 319.10.3		B. Manual pull station/ along path of egress	NFPA 96 11.4.1		
1) Main shut off valve accessible	NFPA 58 6.26.4 1(3)			C. Filters clean / In place	NFPA 96 6.1		
2) Portable containers upright and secure	IFC 319.8			D. UL-300 compliant	NFPA 96 11.2.2		
3) Leak test completed and documented	NFPA 58 6.26.5.1			E. Proper head placement with appliances	NFPA 96 11.2.3.4		
4) Leak test supplies available at event	NFPA 58 6.26.5.1			F. Utility controls / Auto shutoffs installed	NFPA 96 11.3.1		
5) Flex connector at regulator/fixed pipe	NFPA 58 6.26.5.1			<b>SOLID FUEL SAFETY (WOOD, CHARCOAL, OTHER SOLID FUEL USE)</b>			
6) Gas detector installed and tested	IFC 319.8.5	NFPA 58 6.26.5.1		1) No fuel storage above appliances/vents	NFPA 96 15.9.2.2		
7) Container within 10 yr manufacturer date	NFPA 58			2) Fuel storage >3 ft to cooking appliance	NFPA 96 15.9.2.2		
8) Tank Condition (rust, pits, dents, damage)	NFPA 58			3) Fuel storage not near any combustibles	NFPA 96 15.9.2.7		
9) Hose assembly marked for LPG use	IFC 319.8			4) Fuel storage not in path of ash removal	NFPA 96 15.9.2.4		
10) Hose equipped with factory fittings	IFC 319.5			5) Fuel storage not near removed ashes	NFPA 96 15.9.2.4		
11) No CSST Piping installed in trailer/truck	IFC 319.5			6) Firebox emptied minimum once per day	NFPA 96 15.9.3.1		
12) Gas connections/ T's located beneath unit	NFPA 58 6.26.5.1 (J)			7) Ash stored in closed, metal container	NFPA 96 15.9.3.8.1		
13) Grommets around all pipe penetrations	NFPA 58 6.26.5.1(H)3			8) Removed ash > 3 ft. to any appliance	NFPA 96 15.9.3.8.1		
14) ANSI Z 21.69 flexible appliance connector	IFC 319.5			<b>ON SITE EVENT INSPECTION TENT/CANOPY/MEMBRANE STRUCTURE</b>			
<b>LPG CYLINDERS THAT APPEAR TO BE OVERFILLED OR HAVE ANY DISCREPANCIES MUST BE REMOVED FROM THE PROPERTY PRIOR TO THE EVENT</b>				1) Original Manufacture Label present	NFPA 102 10.3		
<b>OPERATIONAL SAFETY</b>				<b>LABEL MUST PROVIDE INFORMATION ON SIZE, FABRIC AND FIRE RESISTANCE RATING</b>			
1) Hot surfaces attended at all times				2) No Smoking / Exit Signs posted	NFPA 102 8.5		
2) Gas valves closed when not in use	NFPA 58 16.9.1			3) No Flammable liquids inside tent / canopy	NFPA 102 8.5		
3) Cooking equipment in clean condition	NFPA 96 12.4			4) No combustible material inside tent / canopy	NFPA 102 8.5		
4) Operate units with vents / window open	NFPA 96 12.1.1			5) Properly secure / fastened down	NFPA 102 8.4		
				6) Protective barrier around generator			

This APPROVED inspection form is valid until December 31 of this year. Any modifications or alterations of appliances, operating procedures, or safety equipment may void this permit, and the Fire Marshal's office shall be notified to schedule a reinspection.

**CORRECTIVE ACTION SHALL BE CARRIED OUT IMMEDIATELY TO CORRECT ALL VIOLATIONS NOTED.**

**THE FIRE MARSHAL'S OFFICE DOES NOT GRANT PERMISSION OR APPROVAL OF A BUSINESS/OPERATION WHERE VIOLATIONS EXIST.  
 NOTIFY THIS OFFICE AS CORRECTIVE ACTIONS ARE COMPLETED.**

RE OFFICIAL: \_\_\_\_\_ OCCUPANT: \_\_\_\_\_